



**Connecticut Department of
Energy & Environmental Protection**
Bureau of Materials Management & Compliance Assurance
Emergency Response & Spill Prevention Division

Class C Operator Refresher Training Course Criteria

Training Course: _____

Provider: _____

- Familiarization with the operator response guidelines, including but not limited to, thorough knowledge of the required response to emergencies and alarms;
- Familiarization with the layout of a typical UST system, as well as familiarity with the particular layout of the UST System or UST Systems at the underground storage facility or facilities at which the Class C Operator has responsibilities;
- Familiarization with reading alarm enunciation panels;
- Certification, signed by the Class A or B Operator or the approved training program, that an appropriately administered and evaluated test demonstrating such knowledge has been passed;
- Requirement for retraining or refresher training at least every 2 years following initial training.
- Exam demonstrating above knowledge.